

Zhejiang Chint Electrics Co., Ltd.
Huang Qin
-
No.1,
Chint Road, Chint Industrial Zone,
North Baixiang
Yueqing, Zhejiang Province 325603
P.R. China

Date : 16.01.2012
Our ref. : WCJ ZC10
Your ref.: H.Q.

Ref : R TÜV-Mark Approval

Type of Equipment : Circuit Breaker
Model Designation : See Certificate
Certificate No. : R 50194667 0001
Report No. : 14705484 001

Dear Huang Qin,

The above specified technical equipment has been tested and found to be in accordance with the relevant requirements.

Enclosed you will find the certificate of approval.

If cancellation of the certificate is submitted by November 15 in a given year, no fee will be charged for the following year.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

Please contact our office for approval of your new products.

With kind regards,

Certification Body


James Li

Enclosure

证书的详细资料请登陆www.tuvdotcom.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50194667

Blatt *Page*
0001

Ihr Zeichen *Client Reference*
H.Q.

Unser Zeichen *Our Reference*
ZC10-WCJ- 14705484 001

Ausstellungsdatum
16.01.2012


Date of Issue
(day/month/year)

Genehmigungsinhaber *License Holder*
Zhejiang Chint Electrics Co., Ltd.
No.1,
Chint Road, Chint Industrial Zone,
North Baixiang
Yueqing, Zhejiang Province 325603
P.R. China

Fertigungsstätte *Manufacturing Plant*
Zhejiang Chint Electrics Co., Ltd.
No.1,
Chint Road, Chint Industrial Zone,
North Baixiang
Yueqing, Zhejiang Province 325603
P.R. China

Prüfzeichen *Test Mark*

Geprüft nach *Tested acc. to*
EN 60947-2:2006



Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Leistungsschalter (Circuit Breaker)

Type Designation : NB1-63DC (Chint) 5
Number of Protection Poles : 1-pole 2-pole 4-pole
Rated Operational Voltage : DC 250V DC 500V DC 1000V
Rated Ultimate Short-circuit
Breaking Capacity (Icu) : 6kA
Rated Service Short-circuit
Breaking Capacity (Ics) : 6kA
Rated Current : 1A, 2A, 3A, 4A, 6A, 10A,
13A, 16A, 20A, 25A, 32A,
40A, 50A, 63A
Utilization Category : A
Rated Insulation Voltage : 1000V
Rated Impulse Withstand Voltage: 4.0kV
Degree of Protection : IP20
Pollution Degree : 3

The labelling requirements acc. to EU Directive 2001/95
have to be observed for distribution within the EEA.


5

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg
Tel.: (+49/221)8 06 - 13 71 e-mail: cert-validity@de.tuv.com
Fax: (+49/221)8 06 - 39 35 http://www.tuv.com/safety

Zertifizierungsstelle



James Li