

ATTESTATION OF CONFORMITY

Issued to: Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang, P. R. China

For the product: Residual current circuit breakers with integral overcurrent protection (RCBO)

Trade name: CHINT

Type/Model: NB310L

Ratings: 3P+N
Ue = 230 / 400 V~, 50 / 60 Hz
In = 6, 10, 13, 16, 20, 25, 32, 40 A, B and C type
IΔn = 30 mA, type A and AC, without time-delay
Ics = Icn = 6 kA, IΔm = Im = 3 kA
Energy limiting class 3 for B and C type

Manufactured by: Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang, P. R. China

Subject: Type Test

Requirements: EN 61009-1:2012 + A1:2014 + A2:2014 + A11:2015 + A12:2016,
EN 61009-2-1:1994 + A11:1998,
IEC 61009-1:2010 + A1:2012 + A2:2013, IEC 61009-2-1:1991

Remark: This Attestation replaces AoC no. 3305783.02AOC issued on 2014-05-09.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in reports no 3305783.50 issued on 2014-04-17 and 3310570.50 issued on 2016-08-30.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Wenzhou, Zhejiang, 08 September 2016 Number: 3310570.01A

DEKRA Testing Services (Zhejiang) Co., Ltd.

Ms J Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed
The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

